



Product Service

CERTIFICATE

No. Z2 16 03 77260 004

Holder of Certificate: **Unimen Solar GmbH**

Mergenthalerallee 79-81
65760 Eschborn
GERMANY



Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Poly-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701261600902-00

Valid until: 2020-05-11



Date, 2016-04-01

(Zhulin Zhang)

Page 1 of 2



Product Service

CERTIFICATE

No. Z2 16 03 77260 004

Model(s):

US200P; US205P; US210P; US215P;
 US220P; US225P; US230P; US235P;
 US240P-60; US245P-60; US250P-60; US255P-60;
 US260P-60; US265P-60; US240P-72; US245P;
 US250P; US255P; US260P; US265P;
 US270P; US275P; US280P; US285P;
 US290P; US295P; US300P; US305P;
 US310P; US315P; US320P

Parameters:

Rated Output Power
 at STC:

200 W, 205 W, 210 W, 215 W,
 220 W, 225 W, 230 W, 235 W,
 240 W, 245 W, 250 W, 255 W,
 260 W, 265 W, 240 W, 245 W,
 250 W, 255 W, 260 W, 265 W,
 270 W, 275 W, 280 W, 285 W,
 290 W, 295 W, 300 W, 305 W,
 310 W, 315 W, 320 W.

Construction:

Framed, with Junction box,
 Cable and Connectors.

Test Laboratory:

Yangzhou Opto-Electrical
 Products Testing Institute
 No.10 West Kaifa Road, Yangzhou,
 225009 Jiangsu, P. R. China

Application Class:

Class A

Maximum System Voltage:

1000 V DC

Fire Safety Class:

Class C

**Tested
 according to:**

IEC 61215(ed.2)
 EN 61215:2005
 IEC 61730-1(ed.1);am1;am2
 EN 61730-1:2007/A2:2013
 IEC 61730-2(ed.1);am1
 EN 61730-2:2007/A1:2012

**Production
 Facility(ies):**

73344

Page 2 of 2